



## BULETIN DE ANALIZA

analize apa

Nr. 648 / 22.03.2019

Identificare client: SC CUP FOCSANI - SUCURSALA ADJUD - INSTALATIA RUGINESTI  
 Recoltat de: Gheorghiu Anisoara  
 Data recoltarii probelor: 19.03.2019  
 Data primirii probelor: 19.03.2019 Intervalul executarii analizelor: 19.03.2019 - 22.03.2019  
 Scopul solicitarii: Monitorizare operationala  
 Document insotitor: P.V.31/19.03.2019  
 Observatii:

| Cod proba | Tipul probei                | Mod prezentare, abateri |
|-----------|-----------------------------|-------------------------|
| 1776      | Apa potabila / BAZINUL NR.1 | Sticla sterila 250 ml   |
| 1777      | Apa potabila / BAZINUL NR.2 | Sticla sterila 250 ml   |
| 1778      | Apa potabila / BAZINUL NR.3 | Sticla sterila 250 ml   |

### REZULTATELE ANALIZELOR EFECTUATE PROBA: 1776

| Parametrii determinati / Metoda de analiza  | U.M.      | Concentr. max. admisa | Val. determinata |
|---|-----------|-----------------------|------------------|
| Nr de colonii la 22°C / SR EN ISO 6222:2004 | ufc/ml    | Max 100               | 5                |
| Nr de colonii la 37°C / SR EN ISO 6222:2004 | ufc/ml    | Max 20                | 1                |
| Bacterii coliforme / SR EN ISO 9308-1:2015  | ufc/100ml | 0                     | 0                |
| Enterococi / SR EN ISO 7899-2:2002          | ufc/100ml | 0                     | 0                |
| Escherichia Coli / SR EN ISO 9308-1:2015    | ufc/100ml | 0                     | 0                |

### REZULTATELE ANALIZELOR EFECTUATE PROBA: 1777

| Parametrii determinati / Metoda de analiza  | U.M.      | Concentr. max. admisa | Val. determinata |
|---|-----------|-----------------------|------------------|
| Nr de colonii la 22°C / SR EN ISO 6222:2004 | ufc/ml    | Max 100               | 5                |
| Nr de colonii la 37°C / SR EN ISO 6222:2004 | ufc/ml    | Max 20                | 2                |
| Bacterii coliforme / SR EN ISO 9308-1:2015  | ufc/100ml | 0                     | 0                |
| Enterococi / SR EN ISO 7899-2:2002          | ufc/100ml | 0                     | 0                |
| Escherichia Coli / SR EN ISO 9308-1:2015    | ufc/100ml | 0                     | 0                |

### REZULTATELE ANALIZELOR EFECTUATE PROBA: 1778

| Parametrii determinati / Metoda de analiza  | U.M.   | Concentr. max. admisa | Val. determinata |
|---|--------|-----------------------|------------------|
| Nr de colonii la 22°C / SR EN ISO 6222:2004 | ufc/ml | Max 100               | 5                |
| Nr de colonii la 37°C / SR EN ISO 6222:2004 | ufc/ml | Max 20                | 1                |

**DIRECTIA DE SANATATE PUBLICA A JUDETULUI VRANCEA  
LABORATOR DIAGNOSTIC SI INVESTIGARE IN SANATATEA PUBLIC**

FOCSANI , Bd. Garii nr. 14

Tel 0237 225979 / 0237 225606 , Fax 0237 227235

[www.dspvn.ro](http://www.dspvn.ro)

e-mail [dspvn@aspvn.ro](mailto:dspvn@aspvn.ro)

acreditat pentru

ÎNCERCARE



SR EN ISO/CEI 17025 2005  
CERTIFICAT DE ACREDITARE  
LI 1158

**BULETIN DE ANALIZA**

**analize apa**

**Nr. 648 / 22.03.2019**

|  |           |   |   |
|--|-----------|---|---|
| Bacterii coliforme / SR EN ISO 9308-1:2015 | ufc/100ml | 0 | 0 |
| Enterococi / SR EN ISO 7899-2:2002         | ufc/100ml | 0 | 0 |
| Escherichia Coli / SR EN ISO 9308-1:2015   | ufc/100ml | 0 | 0 |

**OBSERVATII ASUPRA METODELOR DE ANALIZA:**

Incert.de masurare log.:NTG 22-0,036;NTG 37-0,112;BC-0,034;E.C.-0,074;S.F.-0,12

Dr. CARMEN STANCIU  
medic primar  
medicina de laborator  
COD 419801

SEF LABORATOR : Dr. CARMEN STANCIU

RESPONSABIL ANALIZA: Biolog pr. NICULINA PAVEL

LUCRAT DE: As.Bratosin Anca

PAVEL NICULINA  
BIOLOG PRINCIPAL  
COD 371925

Buletinul se refera la probele prezentate. Se interzice reproducerea partiala a buletinului de analiza.  
Redactat in 2 exemplare.Difuzat la:1 exemplar la DSP Vrancea-Lab. de Microbiologie si 1 exemplar la client.  
Sfarsitul buletinului de analiza.